

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

December 8, 2014

NORWESCO, INC. ANASTASIA R. O'HARA PO BOX 439 ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE

Manufacturer: NORWESCO, INC.

Product Name: HOLDING

Model Number(s): 2500 GAL. (PART NOS. 44079 AND 42119)

[40 IN. L.L., 24 IN. MAX. DEPTH OF BURY; 2550 GAL. ACTUAL CAPACITY]

Product File No: 20140296

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2019.

This approval supersedes the approval issued on 8/14/2013 under product file number 20130223.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- Before this product is installed a warning label meeting the requirement of SPS s. 384.25 (8) (b), Wis. Admin. Code must be securely attached to the manhole cover.
- This product may not be installed where saturated or seasonal saturated soil conditions exist above the inlet of the tank.
- Bedding: This tank must be bedded in well-compacted sand; 6 in. min. in soil terrain; 12 in. min. in rock terrain.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S. POWTS Product Reviewer phone: (608) 267-5265 fax: (608) 267-9723 email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction

SBD-10564-E (N.10/97) File Ref: 14029601.DOC